









1" STANDARD






14" 1/6" HIGH CAPACITY



BIO 2



BIO 3



MODEL	11" STND	14" HICAP	16" HICAP	BIO 2	BIO 3
LENGTH (A)	76"	76"	76"	87"	87"
EFFECTIVE LENGTH (B)	75"	75"	75"	86"	86"
SIDE WALL HEIGHT (C)	6.4"	9.7"	11.2"	9.0"	9.0"
OVERALL HEIGHT (D)	11"	14"	16"	12"	12"
OVERALL WIDTH (E)	34"	34"	34"	15"	22"
CAPACITY	9.2CF (68.8GAL)	11.91CF (89.0GAL)	13.6CF (101.7GAL)	5.0CF (37.4GAL)	8.5CF (63.6GAL)

NOTE: UNIT CONFIGURATION AND AVAILABILITY SUBJECT TO CHANGE WITHOUT NOTICE. PRODUCT DETAIL MAY DIFFER SLIGHTLY FROM ACTUAL PRODUCT APPEARANCE.

© 2007 HANCOR, INC.

HANCOR, INC. HAS PREPARED THIS DETAIL BASED ON INFORMATION PROVIDED TO HANCOR. THIS DRAWING IS INTENDED TO DEPICT THE COMPONENTS AS REQUESTED. HANCOR HAS NOT PERFORMED ANY ENGINEERING OR DESIGN SERVICES FOR THIS PROJECT, NOR HAS HANCOR INDEPENDENTLY VERIFIED THE INFORMATION SUPPLIED. THE INSTALLATION DETAILS PROVIDED HEREIN ARE GENERAL RECOMMENDATIONS AND ARE NOT SPECIFIC FOR THIS PROJECT. THE DESIGN ENGINEER SHALL REVIEW THESE DETAILS PRIOR TO CONSTRUCTION. IT IS THE DESIGN ENGINEER'S RESPONSIBILITY TO ENSURE THE DETAILS PROVIDED HEREIN MEETS OR EXCEEDS THE APPLICABLE NATIONAL, STATE, OR LOCAL REQUIREMENTS AND TO ENSURE THAT THE DETAILS PROVIDED HEREIN ARE ACCEPTABLE FOR THIS PROJECT.

BIOFILTER PRODUCT DETAILS

REV.	DESCRIPTION	BY	MM/DD/YY	CHKD

DRAWING NUMBER: STD-909

HANCOR
401 OLIVE ST.
FINDLAY, OHIO 45839

DATE	02/25/07
SCALE	NTS
SHEET	1 OF 1